

**BARTON HILLS VILLAGE
WASHTENAW COUNTY, MICHIGAN**

ORDINANCE NO. 30

[An ordinance to amend Section 4c of Ordinance No. 29 (Geothermal Systems)]

Barton Hills Village ordains that Section 4c of Ordinance Number 29 be amended to read as follows.

Section 4. Closed Loop Geothermal System Permitted: A person may install and operate a closed loop geothermal system only in accordance with the requirements of this section.

- a. A permit must be approved by the County of Washtenaw.
- b. A permit must be approved by the Village Board of Trustees upon a finding that the system complies with this section.
- c. The systems shall be tested hydrostatically at one and one half times the maximum system design pressure, ~~but not less than 100 psi~~. The duration of each test shall be not less than 15 minutes. All geothermal systems must be pressure checked to the original standard by a licensed geothermal contractor, every three (3) years from the certification system date. Results from the test shall be submitted to the Board of Trustees. No person shall operate a system if a test reveals that it is likely to leak the heat transfer liquid.

Date Adopted: May 11, 2009
Date Published: May 16, 2009
Date Effective: May 17, 2009

Forrest Butterwick, Clerk
Adele P. Laporte, President